



Level 1

RADIANT HEAT FLOOR - 1/2" PEX  
9" O.C SPLIT INTO 4 ZONES  
OFFICE TO INCLUDE (1) 36'x48'  
RADIATOR + 1 TPE RICK RADIATOR W/  
BLOWER. WASHROOM TO INCLUDE  
(1) 36" x 32"

(6) MITSUBISHI  
MZ-GE24 NA  
TYPICAL IN SHOWROOM  
24,000 BTU  
EACH UNIT REQUIRES  
A 20 AMP 208-230V CIRCUIT

PANASONIC 80 CFM  
WHISPER VANCE LITE

Whisper 1

Whisper 2

WEIL-MCLAIN EVERGREEN  
299,000 HW 95% BOILER  
3/4" GAS CONNECTION  
115 VOLT

WEIL-MCLAIN AQUA PLUS 39.9 GAL.  
INDIRECT FIRED WATER HEATER

PANASONIC  
WHISPER LEVINE  
110 CFM

REZTOR EHC-1  
120 V. WALL ELEC. HEATER

Wash Area

VENTILATION  
(2) FANTECH FADE 1839 CFM  
(2) FANTECH MUAS 2000 CFM  
INTAKE MAKE UP AIR SYSTEM  
LOCATIONS TO BE DETERMINED

Break Room

MITSUBISHI HEAT PUMP  
MZ-GE12NA 12,000 BTU

Job #: 1428 Hillgrove  
Performed by Konrad Witek for:

Samuel Girgis  
1428 Hillgrove Ave  
Western Springs, IL 60558  
Phone: 630-886-5339  
srgirgis2@mac.com

Scale: 1 : 150

Page 1  
Right-Suite Universal  
8.0.24 RSU01301  
2016-Aug-09 11:18:01  
...right-load Calcs\1428 Hillgrove.rup